



DATE..... 03-23-98 SCALE..... 1"=100' FILE..... LATUM NO.

- 1) THE UTILITIES AND THEIR LOCATION SHOWN ON PLANS ARE APPROXIMATE. THE CONTRACTOR SHALL VERIFY ALL UTILITIES IN THE FIELD AND NOTIFY ALL UTILITY COMPANIES PRIOR TO INSTALLATION OF THE WATER LINE.
- 2) ALL PIPING SHALL BE CLASS 200 PVC UNLESS OTHERWISE NOTED.
- 3) 42" MINIMUM COVER REQUIRED OVER TOP OF WATER LINE.
- 4) LOCATION OF AIR RELEASE VALVES IS APPROXIMATE AND SHALL BE LOCATED AND INSTALLED BY THE CONTRACTOR AT THE HIGH POINT ALONG THE WATER LINE.

5). ALL WATER LINES ARE TO BE LOCATED AS FOLLOWS:

- a). ON STATE HIGHWAY R/W; 5 FEET INSIDE R/W LINE.
- b). ON COUNTY HIGHWAY R/W; 5 FEET INSIDE R/W LINE.
- c). ON TOWNSHIP HIGHWAY R/W; 5 FEET INSIDE R/W LINE.
- d). ON PRIVATE PROPERTY; ON THE CENTERLINE OF 10 FOOT PERMANENT EASEMENT.
- e). ANY EXCEPTIONS TO THE ABOVE LISTED DISTANCE WILL BE NOTED ON THE PLANS OR EASEMENTS.

GRW PROJECT NO. 2543
CONTRACT NO. MALLARD Dr

DRAWN:	DATE: DEC. 12 1997
TRACED:	SCALE: 1" = 400'
CHECKED:	SHEET NO.
APPROVED:	

DRAWN:	DATE: DEC. 12 1997
TRACED:	SCALE: 1" = 400'
CHECKED:	SHEET NO.
APPROVED:	