

- Fire Hydrant -

Location - Kanawha Terrace and Observatory Drive

Manufacturer - Iowa Steamer

Size -

Flow Rate - Pitot 60

Pressure - Static 115 Residual 60 R.P. at 20 delivers 1756

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/13/87 WC

8/15/88 WC

4/27/89 OW

Note any problems -