

21-1

N1E3

- Fire Hydrant -

Location - 2625 Kanawha Terrace at Sweet Acres Drive

Manufacturer - M & H

Size

Flow Rate - Pitot 60

Pressure - Static 110 Residual 60 R.P. at 20 delivers 1800

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/17/87 WC

8/15/88 WC

9/19/88 WC PERMIT

4/27/89 DW

Note any problems -