

3-1

N1E4

-- Fire Hydrant -

Location - Washington Avenue and Spruce Street

Manufacturer - M & H

Size -

Flow Rate - Pitot 60

Pressure - Static 110 Residual 60 R.P. at 20 delivers 1800

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/16/88 WC

8/23/88 WC Rebuilt

4/24/89 DW

Note any problems -