

17-1

N1W2

- Fire Hydrant -

Location - Baier Street and Oakland Avenue

Manufacturer - Iowa Steamer

Size -

Flow Rate - Pitot 36 = 1008 GPM

Pressure - Static 85 Residual 40 R.P. at 20 delivers 1242 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/24/87 WC
7/25/88 WC
3/27/89 DW

Note any problems -