

~~19-1~~
19-1

- Fire Hydrant -

N1W3

Location - 1230 Highland Drive (East side of Water Tank)

Manufacturer - ~~IWSA~~ M & H 3-Way

Size - 2-3" 1-6"

Flow Rate - Pitot 15 = 650 GPM

Pressure - Static 20 Residual 15

Color Code: Orange

Date Checked and by Whom

7/29/87 WC

7/25/88 WC

3/27-89 DW

Date Checked and by Whom

Date Checked and by Whom

Note any problems -