

3-1

N1W3

- Fire Hydrant -

Location - Elm Street and Edgehill Drive

Manufacturer - M & H

Size -

Flow Rate - Pitot 15 = 650 GPM

Pressure - Static 45 Residual 15

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/27/87

7/25/88

3/27/89 NW

Note any problems -