

11-1

N1W4

- Fire Hydrant -

Location -

Margaret Street and Highland Drive

Manufacturer -

M & H

3-Way

Size -

2-2½"

1-4½"

Flow Rate -

Pitot 20 = 751 GPM

Pressure -

Static 32

Residual 20

R.P. at 20 delivers 751 GPM

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

2/22/87 WC

2/25/87 WC

3/27/87 OW

Note any problems -