

16-1

N2E1

- Fire Hydrant -

Location - Hudson Street and Monroe Avenue

Manufacturer -

Iowa Steamer

3-WAY

High School

2 1/2"

4 1/2"

Size -

Flow Rate -

Pitot 60

Pressure -

Static 110

Residual 60

R.P. at 20 delivers 1800

Color Code: Green

Date Checked and by Whom

8/16/88 WC

4/24/89 OR

Date Checked and by Whom

Date Checked and by Whom

Note any problems -