

15-1

- Fire Hydrant -

N2E4

Location - Spruce Street and Morrell Avenue

Manufacturer -

~~Iowa Steamer~~

KENNEDY

3-WAY

Size -

Flow Rate - Pitot 60

Pressure -

Static 110

Residual 60

R.P. at 20 delivers 1800

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

4/27/88 WC Painted

8/17/88

4/25/89 DW

Note any problems -