

11-1

N2W1

- Fire Hydrant -

Location - Clark Drive at Benedict Circle

Manufacturer - Kennedy 3-Way

Size - 2½"

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 106 Residual 60 R.P. at 20 delivers 1822 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/27/87 WL

7/28/87 WL

3-28/89 NW

Note any problems -