

10=1

N2W2

- Fire Hydrant -

Location - Washington Street and Kanawha Terrace

Manufacturer - Ludlow 2-Way 2-3"

Valve 3 ft. right side
in Concrete

Size - 2½"

Flow Rate - Pitot 50 = 1188 GPM

Pressure - Static 105 Residual 50 R.P. at 20 delivers 1505 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/28/87 WC

7/25/88 WC

3-28-89

Note any problems -