

19-1

N2W3

- Fire Hydrant -

Location - Randy Ritenour at end of Edgehill

Manufacturer - Waterous (New)

Size -

Flow Rate - Pitot 20 = 751 GPM

Pressure - Static 45 Residual 20 R.P. at 20 delivers 751 GPM

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/25/88 WC

8-25-89 OW

Note any problems -