

12-1

N2W5

- Fire Hydrant -

Location - At end of College Hill Road (1056)

Manufacturer - M & H (New) 1-6" 2-3"

Size -

Flow Rate - Pitot 32 = 920 GPM

Pressure - Static 60 Residual 35 R.P. at 20 delivers 1161 GPM

Code: Green

Date Checked and by Whom

7/25/84 WC

3-29-89 OW

Date Checked and by Whom

Date Checked and by Whom

Note any problems -