

- Fire Hydrant -

Location - Washington Avenue (Belvil School Parking Lot)

Manufacturer - M & H (1981) 3-Way

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 117 Residual 70 R.P. at 20 delivers 1921 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/30/87

7/26/88 NC

8/29/89 OW

Note any problems -