

7-1

- Fire Hydrant -

N3W1

Location - Abney Street and Lincoln Avenue

Manufacturer - M & H

Size - 6"

Flow Rate - Pitot 58 = 1278 GPM

Pressure - Static 105 Residual R.P. at 20 delivers 1815 GPM

Color Code: Green

Date Checked and by Whom	Date Checked and by Whom	Date Checked and by Whom
7/30/87 WC Painted		
7/25/88 WC		
3/28/89 DW		

Note any problems -