

8- 1

N3W2

- Fire Hydrant -

Location - Washington Avenue and Drew Street

Manufacturer - M &amp; H

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 115 Residual 80 R.P. at 20 delivers 2000 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/30/87 WC

7/26/88 REG. IT WC

3/29/89 ON

Note any problems - Y