

- Fire Hydrant -

Location - Kanawha Terrace at Central School

Manufacturer - M & H 3-Way

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 105 Residual 60 R. P. at 20 delivers 1840

Color Code: Green

Date Checked and by Whom	Date Checked and by Whom	Date Checked and by Whom
7/31/87 WC		
7/28/88 WC		
3/30/89 DW		

Note any problems -