

7-1

N3W4

- Fire Hydrant -

Location - Highland Drive and Ninth Avenue

Manufacturer - Waterous (New)

Size -

Flow Rate - Pitot 56 = 1256 GPM

Pressure - Static 87 Residual 60 R. P. at 20 delivers 2000

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

6/24/87

7/31/87

7/26/88

8/29/89 DW

Note any problems -