

9-1

N3W5

Location - "B" Street (Rear of Water Plant) - Fire Hydrant -

Manufacturer - Iowa Steamer

Size - 2½"

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 105 Residual 60 R. P. at 20 delivers 1840 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

7/31/87 WC

7/28/88 WC

3/30/89 DW

Note any problems -