

1-1

- Fire Hydrant -

N4E1

Location - MacCorkle Avenue and Fairfield (Harvey Shreve)

Manufacturer -

Size -

Flow Rate - Pitot 60

Pressure - Static 110 Residual 60 R.P. at 20 delivers 1800

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/25/88 WC REBUILT
4/26/89 on

Note any problems -