

24-1

- Fire Hydrant -

114E1

Location - Hudson Street and Harrison Avenue

Manufacturer - M & H

Size -

Flow Rate - Pitot 60

Pressure - Static 112 Residual 60 R.P. at 20 delivers 1776

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/19/88 WC

4/26/89 OW

Note any problems -