

10-1

N4W1

- Fire Hydrant -

Location - Grant Avenue and Custer Street

Manufacturer - M & H

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 112 Residual 58 R. P. at 20 delivers 1738 GPM

Date Checked and by Whom

Date Checked and by Whom

Color Code: Green

Date Checked and by Whom

7/31/57 WC

7/28/58 WC

3-30-59 DW

No te any problems -