

7-1

N4W1

- Fire Hydrant -

Location - Corner of Jackson Avenue and Carson Street

Manufacturer - M & H

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 113 Residual 60 R. P. at 20 delivers 1776 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/1/87 WC

7/28/88 WC

8-30-89 DW

Note any problems -