

4-1

- Fire Hydrant -

NW2

Location - Beside Water Company Garage (K-Mart Lot)

Manufacturer - Mueller

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 110 Residual 60 R. P. at 20 delivers 1799 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date checked and by Whom

8/3/77 WC

8/10/88 WC

4/4/89 DW

Note any problems -