

8-1

- Fire Hydrant -

N4W2

Location - Behind 1447 in Mall

Manufacturer - Mueller

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 110 residual 60 R. P. at 20 delivers 1798

Date Checked and by Whom

Date Checked and by Whom

Color Code: Green

Date Checked and by Whom

8/1/87 WC

7/28/88 WC

4/3/89 DW

Note any problems -