

~~1~~
9-1

N4W2

- Fire Hydrant -

Location - Corner of K-Mart Lot

Manufacturer - Mueller

Size -

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 110 Residual 60 R. P. at 20 delivers 1798 GPM

Color Code: Green

Date Checked and by Whom -

Date Checked and by Whom

Date Checked and by Whom

8/1/87 WC

1/22/88 WC

1/3/89 DW

Note any problems -