

18-1

- Fire Hydrant -

N4W4

Location - 616 Sixth Avenue

Manufacturer - ~~Iowa Steamer~~ MSH (NEW) 1992

Size -

Flow Rate - Pitot 18 = 712 GPM

Pressure - Static 110 Residual 20 R. P. at 20 delivers 712 GPM

Date Checked and by Whom

Date Checked and by Whom

Color Code: Orange

Date Checked and by Whom

8/1/87 WC

8/1/88 WC

4/5/89 DW

Note any problems -