

7-1

Location - Sixth Street and MacCorkle Avenue - Fire Hydrant -

N5W3

Manufacturer - M & H 3-Way

Size - 2-3" 1-6"

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 110 Residual 60 R. P. at 20 delivers 1799 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/3/87 WC

8/11/88 WC

4/4/89 DW

Note any problems -