

24-1

- Fire Hydrant -

N5W4

Location - Sixth Street and Fourth Avenue (Lantz Lumber Co.)

Manufacturer - M & H

Size -

Flow Rate - Pitot 19 = 731 GPM

#496⁰⁰

Pressure - Static 112 Residual 20 R. P. at 20 delivers 731 GPM

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom