

3-1

- Fire Hydrant -

N5W4

Location - MacCorkle Avenue and Third Street (Rax Restaurant)

Manufacturer - Kennedy 3-Way

Size - 2½"

Flow Rate - Pitot 60 = 1300 GPM

Pressure - Static 115 Residual 58 R. P. at 20 delivers 1720 GPM

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/3/87

8/11/88

WC

4/4/89

DW

Note any problems -