

- Fire Hydrant -

Location - "B" Street at Police Station and Fire Department

Manufacturer - Kennedy

3-2/4Y

2-2 1/2"

1-4 1/2"

Size -

Flow Rate - Pitot 20

PRESSure - Static 110 Residual 20 R. P. at 20 delivers 751

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

5/4/87 WC

8/12/88 WC

4/5/89 DW

Note any problems -