

23-1

N5W5

- Fire Hydrant -

Location - "C" Street at First Baptist Church

Manufacturer - M & H

Size -

Flow Rate - Pitot 19

Pressure - Static 112 Residual 20 R.P. at 20 delivers 731

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8/3/87 WC

8/12/88 WC

10/3/88 WC

4/5/89 DW

Note any problems -