

5-1

5-1?

- Fire Hydrant -

N5W5

Location - "C" Street and Fourth Avenue

Manufacturer - M & H

Size --

Flow Rate - Pitot 18

Pressure - Static 110 Residual 20
Residual Pressure at 20 delivers 712

Color Code: Orange

New Hydrant installed November 20, 1989