

0-1

3' Frost

Dry Ridge
SLOW

- Fire Hydrant -

Location - *Beside Weatherholt House*

#3

Manufacturer - *American Darling 1979*

Size -

Flow Rate - Static 90 Pitot 20

Pressure - Residual Pressure 20 Residual at 20 delivers 751

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

*6/26/88 WC Painted**5/5/89 NW*

Note any problems -