

9-1.

Dry Pipe
SIDE1Location - ^{Close to} GREEN VALLEY ENTRANCE - Fire Hydrant - #4

Manufacturer - AMERICAN DARLING

Size -

Flow Rate - Static 65 Pitot 8

Pressure - Residual Pressure 8 Residual at 20 delivers 475

Color Code: Red

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

6/26/88 Painted WC

5/5/89 DW

Note any problems -