

3-1

- Fire Hydrant -

O/T

S10W7

Location - Riverbend Boulevard 156

Manufacturer - Mueller

Size -

Flow Rate - 11 lbs = 556 GPM

Pressure - STATIC - 110

R.P. 32

Date Checked and by Whom	Date Checked and by Whom	Date Checked and by Whom
3-22-89 D.T.W.		

Note any problems -