

22-1

- Fire Hydrant -

S1E1

Location - Intersection of Observatory Drive and Valley Pike Drive

Manufacturer - M & H

Size - 2 1/2"

Flow Rate - Static 90 Pitot 48

Pressure - Residual Pressure 48 Residual at 20 delivers 1520

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

4/25/88 we Painted

5/3/89 DW

Note any problems -