

5-1

- Fire Hydrant -

S1E1

Location - Observatory Drive at Top of Hill

Manufacturer - M & H

Size - 4 1/2"

Flow Rate - Static 80 Pitot 16

Pressure - Residual Pressure 16 Residual at 20 will deliver 672

Date Checked and by Whom

4/25/88 wc Paintsd
5/2/89 ow

Date Checked and by Whom

Color Code: Orange

Date Checked and by Whom

Note any problems -