

11-1

S1E2

- Fire Hydrant -

Location - 825 Poplar Street

Manufacturer - Iowa Steamer

3-way

No Value

Size - 1 1/4" 2 2 1/2"

Flow Rate - Static 95 Pitot 58

Pressure - Residual Pressure 58 Residual at 20 delivers 1860

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

4/25/88 wa Painted

5/3/89 DW

1/30/90 OK EAP

Note any problems -