

7-1

- Fire Hydrant -

S1E2

Location - 906 Vine Street and Valley Pike Drive

Manufacturer - M & H

3-WAY

2 1/2" x 4 1/2"

Size -

Flow Rate - Static 98 Pitot 60

Pressure - Residual Pressure 60 Residual at 20 delivers 1920

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

5/3/89 DW

Note any problems -