

- Fire Hydrant -

11-1

SLE3

Location - End of Wildwood Circle At Hughes Drive

Manufacturer - M & H (Replaced Iowa Steamer 1-8-90)

Size -

Flow Rate - Static 60 Pitot 30

Pressure - Residual Pressure 30 Residual at 20 delivers 1080

Code: Green

Note any problems -