

2-1

- Fire Hydrant -

SLE3

Location - Sweet Acres Drive

Manufacturer - M & H (Replaced R.D. Wood)

Size 4"

Flow Rate - 444 GPM

Pressure - Static 95      Residual Pressure 3 = 92 PD

Pitot 7

PD 20# = 411 GPM

Note any problems -