

S1E4

12-1

- Fire Hydrant -

Location - Young's Trailer Court - Kanawha Terrace

Manufacturer - M & H

Size -

Flow Rate - Static 110 Pitot 60

Pressure - Residual Pressure 60 Residual at 20 delivers 1790

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

4/29/89 WC Printed

5/3/89 GW

Note any problems -