

- Fire Hydrant -

Location - Sutherland Drive and Ellis Road

Manufacturer - M & H

Size - 6" 2-2" 1-5½"

Flow Rate - Static Pressure (35) Pitot (24) 823 GPM = 1.8 ^{cu} FPS

Pressure - Residual Pressure 23 Residual at 20 delivers 920 GPM

Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

6/29/88 nc Painted

4/26/89 nw

Note any problems -