

22-1

SLW1

- Fire Hydrant -

Location - Dryridge Apartments at Entrance

Manufacturer - Kennedy

Size -

Flow Rate - Static 80 Pitot 26

Pressure - Residual Pressure 26 Residual at 20 will deliver 900

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

6/3/88 WC Painted

4/26/89 DW

Note any problems -