

4-1

S1W2

- Fire Hydrant -

Location - Baier Street and Woodside Drive

Manufacturer - Kennedy 3-WAY

Size - 6" MAIN

Flow Rate - Static 135 145 Pitor 56 52 ^{GPM} 1205 - 2.7 ^{CV} FPSPressure - Residual Pressure ~~70~~ 50 Residual Pressure at 20 will deliver 1717

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

6/29/58 WL Painted

4/26/59 DW

Note any problems -