

24-1

S2E2

- Fire Hydrant -

Location - Summitt Drive (1124)

Manufacturer - Iowa Steamer

3-WNY

Size - 2 1/2"

Flow Rate - Static 40 Pitot 24

Pressure - Residual Pressure 24 Residual at 20 delivers 921

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

5/4/89 DW

Note any problems -