

- Fire Hydrant -

Location - Wildwood Circle and Hughes Drive

Manufacturer - M+H 1-6" 2-3" This one replaced the
Size - Iowa (148-90 Not SIE3 11-1)

Flow Rate - Static 80 Pitot 50 29

Pressure - Residual Pressure 50 889 - ORANGE Code
Residual at 20 delivers 1742

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

10/29/87 WC

5/4/89 DW

Note any problems -