

7-1

- Fire Hydrant -

S2W1

Location - Dry Ridge Road at Now Corporation

Manufacturer - Kennedy 3-WAY

Size - 2 1/2

Flow Rate - Static 65 Pitot 26

Pressure - Pressure Residual 26 Residual at 20 will deliver 920

Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

6/3/88 we Painted

5/2/89 OW

Note any problems -